



UNIVERSITÀ
DEGLI STUDI
FIRENZE

FLORE

Repository istituzionale dell'Università degli Studi di Firenze

Indoor Air Quality in the Uffizi Gallery of Florence: Sampling, Assessment and Improvement Strategies

Questa è la Versione finale referata (Post print/Accepted manuscript) della seguente pubblicazione:

Original Citation:

Indoor Air Quality in the Uffizi Gallery of Florence: Sampling, Assessment and Improvement Strategies / Fabio Sciarpi; Cristina Carletti; Gianfranco Cellai; Cristina Piselli. - In: APPLIED SCIENCES. - ISSN 2076-3417. - ELETTRONICO. - 12:(2022), pp. 1-20. [10.3390/app12178642]

Availability:

The webpage <https://hdl.handle.net/2158/1280423> of the repository was last updated on 2022-09-27T08:11:01Z

Published version:

DOI: 10.3390/app12178642

Terms of use:

Open Access

La pubblicazione è resa disponibile sotto le norme e i termini della licenza di deposito, secondo quanto stabilito dalla Policy per l'accesso aperto dell'Università degli Studi di Firenze (<https://www.sba.unifi.it/upload/policy-oa-2016-1.pdf>)

Publisher copyright claim:

Conformità alle politiche dell'editore / Compliance to publisher's policies

Questa versione della pubblicazione è conforme a quanto richiesto dalle politiche dell'editore in materia di copyright.

This version of the publication conforms to the publisher's copyright policies.

La data sopra indicata si riferisce all'ultimo aggiornamento della scheda del Repository FloRe - The above-mentioned date refers to the last update of the record in the Institutional Repository FloRe

(Article begins on next page)

Article

Indoor Air Quality in the Uffizi Gallery of Florence: Sampling, Assessment and Improvement Strategies

Fabio Scirpi , Cristina Carletti, Gianfranco Cellai and Cristina Piselli 

Department of Architecture DIDA, University of Florence, 50121 Florence, Italy

* Correspondence: fabio.scirpi@unifi.it

Abstract: The assessment of indoor air quality (IAQ) in museums is a complex issue. In this study, a comprehensive investigation methodology was defined and applied to a museum to be validated. This methodology includes the analysis of exposed objects, the optimal conditions for conservation, the building features and the HVAC systems, and the indoor thermo-hygrometric and air quality conditions. In 2019, a survey in the Uffizi Gallery of Florence, one of the most important museums in the world, was carried out to assess the IAQ conditions in the museum, and the workers and visitors' well-being, by focusing on some representative rooms (nine) of the museum complex in terms of visitor turnout and HVAC systems, including rooms closed to the public. Since IAQ is related to the possible presence and concentration of chemical and biological pollutants, these indicators, as well as thermo-hygrometric parameters, were monitored. The monitoring results were analyzed, evaluated, and compared with those suggested by the literature, guidelines and legislative documents dealing with IAQ in museums. Monitoring approaches for deepening investigations, as well as guidelines aimed at improving IAQ in the Uffizi Gallery and similar buildings are proposed.

Keywords: indoor air quality; monitoring; museum; cultural heritage; artworks conservation; user well-being



Citation: Scirpi, F.; Carletti, C.; Cellai, G.; Piselli, C. Indoor Air Quality in the Uffizi Gallery of Florence: Sampling, Assessment and Improvement Strategies. *Appl. Sci.* **2022**, *12*, 8642. <https://doi.org/10.3390/app12178642>

Academic Editors: Hugo Entradas Silva, Luísa Dias Pereira and Luís G. Baltazar

Received: 2 August 2022

Accepted: 25 August 2022

Published: 29 August 2022

Publisher's Note: MDPI stays neutral with regard to jurisdictional claims in published maps and institutional affiliations.



Copyright: © 2022 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<https://creativecommons.org/licenses/by/4.0/>).

1. Introduction

In our society, cultural heritage in general, and museums in particular, play a key role as symbols of the past and as a means of safeguarding cultural identity in a continuously changing world. Cultural tourism can be a major contributor to the economy of each country, as well as a potential vehicle to facilitate the preservation of cultural heritage, if properly managed [1,2]. From this perspective, the improvement of indoor air quality (IAQ) in museums is an important challenge as artefacts can be subjected to various types of decay depending on the indoor conditions in the building where they are preserved [3]. On the other hand, comfortable conditions for workers and the visitors must also be guaranteed, requiring compromises between indoor pollution, well-being, preventive conservation, and energy efficiency [4,5]. The indoor temperature and relative humidity greatly influence the occurrence of chemical, biological, and mechanical degradation, as well as affecting thermal comfort [6,7]. Indoor relative humidity and temperature, as well as causing dimensional changes and biological deterioration, can accelerate both physical and chemical damages, such as metal corrosion, discoloration and the hydrolysis of cellulose-based materials, fabrics and paintings.

To achieve and maintain good IAQ, different sources of pollutants must be assessed, such as occupants, building materials, maintenance products, and equipment (HVAC) [8]. In museums, the main parameters that must be measured and evaluated are chemical pollutants, microbiological pollutants, and volatile organic compounds (VOCs) [9,10]. Their effects can be increased if high levels of indoor air temperature, relative humidity, and ventilation effectiveness are improperly controlled inside the museum.

Carbon dioxide (CO₂) and water vapour are emitted from human breath and can be used as an indicator of pollution caused by human beings and of the effectiveness of ventilation in a museum [11]. It has very little adverse effect on collections, though concentrations above 1000 ppm can have adverse effects on human health. Table 1 shows concentration levels of CO₂ and their assessment [12].

Table 1. Concentration levels of CO₂ and their assessment.

Concentration	Assessment
<1000 ppm	Acceptable levels
1000–2000 ppm	High levels
>2000 ppm	Unacceptable levels

Most of the pollutants surveyed in museums belong to the class of VOCs, such as aliphatic, aromatic, and chlorinated hydrocarbons, aldehydes, terpenes, alcohols, esters, and ketones. They can be found in indoor air in relation to the activities performed, to the structural characteristics, to the HVAC system features, and to crowding. In general, the principal sources of VOCs are the occupants, HVAC equipment, air intakes near traffic-polluted areas, cleaning products, draperies, environmental tobacco smoke (ETS), printers and copiers, building materials, and furnishings [12,13]. In Table 2, the most common indoor VOCs are listed with their main sources.

Table 2. Indoor VOCs and main sources.

Classes of Compounds	Main Pollutants	Main Indoor Sources
Aliphatic hydrocarbons	Propane, butane, hexane, limonene	Fuels, detergents, aerosol propellants, refrigerants, perfume bases, flavourings
Halogenated hydrocarbons	Chloroform, methylene chloride, pentachlorophenol	Aerosol propellants, pesticides, refrigerants, degreasers
Aromatic hydrocarbons	Benzene, toluene, xylene	Paints, glues, enamels, lacquers, detergents
Alcohols	Ethyl alcohol, methyl alcohol	Window cleaners, paints, thinners, adhesives, cosmetics
Aldehydes	Formaldehyde, acetaldehyde	Fungicides, thermal insulation, germicides, resins, disinfectants, chipboard furniture

High concentrations of VOCs in indoor environments, that can be two to five times higher indoors than outdoors [14], can cause a wide range of health effects. The most common effects on human health can be caused by short-term as well as long-term exposure to pollutants. An interesting review of the issues related to exposure to cleaning products and air fresheners is provided in [15], where different groupings of substances are identified, including glycols, aliphatic, and aromatic hydrocarbons, aldehydes, ketones, and chlorinated organics. Detergents and sanitizers are often considered non-hazardous, pursuant to regulation 1272/2008 (CLP) [16]. For this reason, the labels and safety data sheets do not report the chemical name of the individual substances, but their general composition (detergent, perfume, etc.). This does not allow for specific determination of the possible contribution of solvents deriving from these uses.

With respect to exposure to indoor air VOCs, the European Guideline COST Project 6 1 3—Report No. 11 [17] reports the values of total volatile organic compounds (VOCs) derived from international studies (Table 3).

For microbiological pollutants, the bioaerosol mainly consists of vital and non-vital biological agents, their metabolites (enzymes and toxins), bacterial and fungal spores and

cysts of protozoa and cyanobacteria, as well as derivatives of plants, humans and animals. The presence of a bioaerosol can cause infectious processes, allergies, or intoxication. The onset of different pathologies related to the bioaerosol depends not only on the presence of outdoor and indoor pollution sources, but also on the ventilation rate of the building and the effectiveness of ventilation on indoor temperature and relative humidity (necessary conditions for the proliferation of microorganisms), the general hygienic conditions of the building, and the type and duration of human exposure [18].

Table 3. Concentration level of VOCs and their assessment.

Concentration	Assessment
<0.200 mg/m ³	Comfort level
0.200–3 mg/m ³	Acceptable level
3–25 mg/m ³	Discomfort level
>25 mg/m ³	Unacceptable toxicity

Moreover, the effects of biological agents and their metabolites must be evaluated not only in relation to their intrinsic characteristics, but also with respect to potential “cocktail” effects that are associated with mixtures of biological and chemical agents. These “cocktail” effects are also related to the following individual characteristics: age, immune system condition, presence or absence of chronic diseases, and lifestyle (sedentary lifestyle, use of narcotic/intoxicating substances, stress levels, etc.) [18].

To ensure acceptable indoor biological quality conditions, constant monitoring of pollutant concentrations, ventilation/air treatment systems and their maintenance/sanitation status must be carried out. For this purpose, air quality indicators that must be analyzed include total bacterial load (TBL) and mold spore levels. Inside museums, the main sources of biological aerosol are usually human beings, though these pollutants can grow in the dust settled in the building and HVAC sections. High TBL levels can also be related to the presence and growth of pathogenic micro-organisms that can potentially cause hazardous diseases for humans (including via infectious processes, allergies or intoxication of occupants).

With respect to the concentration of bacterial and mycotic load in indoor air, the European Guideline COST Project 6 1 3—Report No. 12 [19] presents a classification of pollutants collected using active sampling methods and expressed as CFU/m³ (Table 4). These values can be considered to be reference values for aeraulic system hygienic conditions when samples are collected inside the airduct or close to the vents or anemostats (about 50 cm from the sampler).

Table 4. Microbiological pollution and IAQ assessment.

Pollutant Class	Residential Buildings	Non-Industrial Buildings
Bacterial		
Very low	<100 CFU/m ³	<50 CFU/m ³
Low	<500 CFU/m ³	<100 CFU/m ³
Mean	<2500 CFU/m ³	<500 CFU/m ³
High	<10,000 CFU/m ³	<2000 CFU/m ³
Very high	>10,000 CFU/m ³	>2000 CFU/m ³
Mycetic		
Very low	<50 CFU/m ³	<25 CFU/m ³
Low	<200 CFU/m ³	<100 CFU/m ³
Mean	<1000 CFU/m ³	<500 CFU/m ³
High	<10,000 CFU/m ³	<2000 CFU/m ³
Very high	>10,000 CFU/m ³	>2000 CFU/m ³

Finally, considering conditions for the well-being of people, [20,21] report the typical average values of indoor air temperature, relative humidity, and mean air velocity (Table 5).

Table 5. Typical thermal comfort parameters.

Parameter	Comfort Range—Winter	Comfort Range—Summer
Air Temperature, t [°C]	$19 \div 22$ °C	$24 \div 26$ °C
Relative Humidity, RH [%]	$40 \div 50$ %	$50 \div 60$ %

Currently, there is no specific reference in the Italian national legislation, and no global and integrated policy has been defined in the technical field, for the evaluation of cause-effect associations between the presence, type, and concentration of pollutants and perceived discomfort/health risk, according to the above-mentioned requirements. However, there are some reference technical rules and standards, guidelines, and national and international studies on IAQ [18,22,23] that provide precise indications, e.g., ANSI/ASHRAE standard 62.1-2019 [24], where IAQ is defined as “air in which there are no known contaminants at harmful concentrations, as determined by cognizant authorities, and with which a substantial majority (80% or more) of the people exposed do not express dissatisfaction”.

Since discomfort and health risk are largely related to pollutant concentrations and, therefore, indirectly to the ventilation effectiveness in the rooms, many technical and regulatory provisions deal with minimum values of air flow rates [25,26]. In addition, it is possible to find guidelines dealing with the hygienic maintenance of air handling units (filtration and cleaning) and the ductwork, relating to their inspection and cleaning procedures, and reference values on the concentration of dust, bacteria, and fungi inside the ductwork, as well as reports (mostly published by the Italian National Institute of Health—ISS) which deal with control and regulation in the IAQ arena to protect human health [12,27–29].

In Italy, in museums, the protection of artworks and individuals fall under a very broad regulatory and legislative framework overseen from the Ministry for Cultural Heritage and Activities [30] to the Ministry of Health [31]. Guidelines are also available that are issued by various national public technical bodies, such as the Higher Institute for Prevention and Occupational Safety (ISPESL), the Italian National Health Institute (ISS), and other international bodies, such as the World Health Organization (WHO), the Air Infiltration and Ventilation Center (AIVC), and, finally, ANSES (Agence Nationale de Sécurité Sanitaire de l’Alimentation, de l’Environnement et du Travail—the national agency for health, food, environmental and work safety). The latter, for instance, has drawn up an updated report on CO₂ concentrations. Moreover, the State-Regions conference guidelines are of great interest [32,33]. These documents provide information on the maintenance procedures for HVAC systems and provide for the planning of the hygienic maintenance of aeraulic components, and the frequency of, and strategies for, interventions.

The activity of ISS is of particular interest. In 2010, the National Study Group on Indoor Pollution was formed and issued documents dealing with various aspects of IAQ, such as VOCs in indoor environments [27], monitoring strategies for biological air pollution in indoor environments [28], microclimate parameters and indoor air pollution [29], and the presence of CO₂ and hydrogen sulphide (H₂S) in indoor environments [12].

Finally, considering the close relationship between air quality and HVAC systems, important recommendations have been provided in some documents drafted on hygienic maintenance by associations such as the National Air Duct Cleaners Association (NADCA) and the Italian Association of Aeraulic Systems Hygienists (A.I.I.S.A.) with reference to Italy. In particular, the 2021 NADCA ACR Standard [34] provides practical, reliable and industry-backed information for assessing new and existing HVAC systems, evaluating and verifying the cleanliness of HVAC system components, preventing job-related hazards, and guiding the cleaning and restoration of HVAC systems to a specific level of cleanliness.

Within this panorama, this study sought to assess IAQ in museums based on a defined methodology. The proposed approach was applied and validated in the world-famous museum of the Uffizi Gallery in Florence, Italy. The approach comprised a combination of a survey and short-term monitoring carried out in selected rooms of the museum. The monitoring was undertaken to investigate indoor environmental conditions that have been demonstrated to affect both occupants' well-being and artwork preservation, i.e., air temperature, relative humidity, and chemical and microbiological pollutants. Furthermore, a tailored strategy for the assessment of the monitored data was identified and implemented. The purpose of the proposed approach was to highlight possible critical issues in terms of IAQ in the museum and, as a result, to define guidelines to improve indoor air quality control in museums and to address observed issues.

2. Materials and Methods

2.1. Investigation Strategy

This research builds upon a previous study [35] in which a general investigation strategy for the assessment of the indoor air quality of museums was defined. In the present study, this approach is presented and applied in a case study of a specific museum building. This methodology is based on the following phases:

- (i) collection of general data;
- (ii) definition of monitoring strategies;
- (iii) sampling of indoor parameters;
- (iv) analysis of data and comparison between measured and recommended values;
- (v) IAQ parameter critical analysis and their correlation with possible pollution sources;
- (vi) definition of guidelines and strategies for the improvement of IAQ conditions in museums.

During phase (i), combined with site inspections, primary information about the museum was collected, such as documents and drawings, the characteristics of rooms and the equipment held, the typical presence of visitors in each room, the presence and typology of the HVAC system, the characteristics of the building materials, the characteristics of the objects exposed and their conservation requirements, and the methods of cleaning the environment and the detergents used. Moreover, interviews with technical staff were carried out to identify possible concerns regarding management of the indoor air quality conditions in the museum environment.

During phases (ii) and (iii), the monitoring strategies (instruments used, time of sampling, duration and frequency of sampling, etc.) for the evaluation of indoor air quality were defined, consistent with the research objectives. Moreover, based on the outcomes of phase (i), the reference rooms of the museum to be analyzed and the sampling location inside each room were defined. The analyzed rooms were selected based on various considerations related to the conservation of the artworks, i.e., their importance and the potential critical issues for their preservation, user factors, i.e., the number of visitors and occupants' well-being related to indoor air quality, and the characteristics of the air conditioning system. In each room selected, the monitoring systems were placed in the best location with the purpose of collecting representative data (at a height of 1.5 m from the floor), while limiting visitors' interaction with them, to ensure the proper and undisturbed functioning of the rooms.

Since the museum is visited by many people every day, parameters characterizing air pollution in the rooms of the museum were collected for the selected representative rooms. Furthermore, the principal indoor parameters defining environmental and air quality conditions were collected, such as air temperature, relative humidity, organic (VOCs) and inorganic (CO₂) pollutants, and bacteria aerosols (bacteria and molds).

Measurements were carried out both during the opening hours and the closing hours of the museum. The latter measurements were used as reference values for the conditions without occupants. In this case, monitoring was carried out during a day when the museum was closed to the public and a day when the museum was open to the public (opening hours

8:15 to 18:50), corresponding to a greater number of visitors. The monitoring was carried out before the maintenance of the HVAC systems to assess the most critical conditions.

To monitor the indoor air temperature, relative humidity and CO₂ concentration, a datalogger connected with a psychrometer (air temperature [°C] and relative humidity [%]), and a CO₂ probe [ppm] were used. This microclimate station measured the parameters every minute for 30 min in sequence in each room analyzed. Table 6 summarizes the main features of the microclimate station [35].

Table 6. Main features of the microclimate station.

■ Psychrometer	
Sensor	Pt100 (1/3DIN)
Accuracy	0.10 °C (0 °C); 0.13 °C (20 °C) 2% (15 ÷ 40%); 1% (40 ÷ 70%); 0.5% (70 ÷ 98%)
Response time	90'' (operating fan)
Measurement range	t _{db} *: 25 ÷ 150 °C; t _{wb} **: 0 ÷ 60 °C RH: 0 ÷ 100%
*CO ₂ Probe	
Sensor	Absorption infra-red cell
Accuracy	3% measure range
Response time	<30''
Measurement range	0 ÷ 3000 ppm

* dry bulb temperature; ** wet bulb temperature.



Organic pollutant and bacteria aerosol sampling were carried near the microclimate station [35]. The VOCs were monitored through active sampling of a 5 L air volume in nalophan bags. Subsequently, the collected air volume was analyzed in an external laboratory through quantitative and qualitative VOCs analysis performed according to the gas chromatography-mass spectrometry (GC/MS) method [36]. The cut-off value for VOCs was set equal to 1% of the air sample [37].

Both active and passive methods were used in the biological analysis to sample TBL and molds. Active sampling involved the collection of air flow with a surface air system impactor (sampling rate of 100 L/min). However, the sampling rate and, thus, the total air volume varied from 0.3 to 1 m³, according to the different occupational patterns of the monitored museum room, assuming a potentially higher pollutant concentration in relation to a greater presence of visitors. Passive sampling was used to gather information about the microbial load, using Petri dishes positioned next to the microclimatic station ($\Phi = 90$ mm, plate count agar for microbial growth and Sabouraud dextrose agar for mold growth). The microbial load naturally falls on the plate as an effect of the movement of air (due to both the passage of people and to the air flows from the HVAC systems). Using this method, the total biological pollution was measured for 2 h. At the end of the sampling period, the dishes from the active and passive methods were analyzed in an external laboratory where they were incubated at the required temperature-time range (three days at 30 °C for TBL and five days at 25 °C for molds). Thereafter, the samples were analyzed to determine the CFU for both bacteria and molds according to the ISS Report [28].

During phase (iv) all the sampled and monitored data were post-processed and organized in tables and graphs summarizing the minimum, maximum, and average values of the parameters. The parameters were analyzed for each selected room. For the organic, inorganic, and biological pollutants, the collected data were compared with reference values reported in the analyzed literature and, for the VOCs, also with cut-off values. Similarly, the measured air temperature and relative humidity values were compared with reference values for artwork conservation [30] and for occupants' well-being [20,21].

In phase (v), the results of the data collection were critically analyzed. The correlation of the level of pollutants (i.e., CO₂, VOCs, TBL and molds) with various influencing

variables, including the type of HVAC system, the maintenance procedures, the cleaning procedures, etc., were investigated. In particular, the total bacterial load and total colony forming units (CFUs) in the bioaerosol were assessed.

Finally, the outcomes of phase v) were utilized in phase (vi) to propose strategies and guidelines for the improvement of IAQ in museums.

2.2. The Case Study

The defined methodology was implemented and validated in selected rooms of the Uffizi Gallery Museum in Florence, Italy. This is a large museum that is among the most famous in the world. The Uffizi Gallery hosts priceless artwork collections that include paintings by Italian artists from the 14th-century and the Renaissance (e.g., Leonardo, Raffaello, Giotto, Piero della Francesca, Simone Martini, Filippo Lippi, Beato Angelico, Mantegna, Botticelli, Correggio, Michelangelo, and Caravaggio). Numerous precious works by European painters from the same historic period (mainly Dutch, Flemish, and German), and a collection of ancient statues and busts [35] from the Medici family, are also displayed in the museum. The latter are ancient Roman copies of lost Greek sculptures that adorn the corridors of the Uffizi Gallery. The museum is located on the first and second floors of a valuable historical building in the city center of Florence, designed by Giorgio Vasari and dating back to 1560–1580.

According to the results of phase (i), and due to the insights obtained from the interviews with the technical staff, some Gallery rooms characterized by poor air quality were identified. Therefore, the investigation was carried out for nine representative rooms that are highlighted in Figure 1 and described in detail below.





Figure 1. Plan of the first (a) and the second (b) floor of the Uffizi Gallery pointing out the analyzed rooms.

With respect to the HVAC system serving the building, the Uffizi Gallery is mainly equipped with HVAC systems which recirculate the air, for the control of air temperature and relative humidity, all year. Moreover, the system is managed by a remote monitoring and control system, positioned in a technical room, that also controls the fire system, the security system, and the electrical system. As an example, Figure 2 shows the air handling unit (AHU) control system of Room 2 and some pictures of the room.

On the first floor of the museum, three rooms were considered (Figure 3). The Verone I floor (Figure 3a) has views from every orientation with large windows and mainly hosts ancient statues and busts. Sampling was performed near the north-facing window. The Verone I floor has a floor area of 201.04 m², a height of 8.17 m and a volume of 1642.50 m³. It is equipped with an HVAC system for control all year of temperature

and relative humidity, managed by a remote monitoring and control system. The primary ventilation air comes from the AHU, using supply fans with variable flow (nominal air flow rate of 1400 m³/h), and enters the room through floor inductors. There is no recirculated air.



(a)



(b)



(c)



(d)

Figure 2. (a) AHU control system scheme, (b) AHU in the attic room, (c) air inlet grids from the top of the roof, and (d) air outlet grids at the bottom of the opposite wall of Room 2.



(a)



(b)



(c)

Figure 3. Analyzed rooms on the first floor of the Uffizi Gallery: (a) Verone I floor, (b) Room 41 and (c) Room 160.

Room 71 (Figure 3b) has non-external walls. Inside the room, the “Scudo con testa di Medusa” of Michelangelo Merisi from Caravaggio is displayed, an oil painting on canvas (1597). Samplings were carried out near the painting. The room has a floor area of 69.28 m², a height of 8.02 m and a volume of 555.62 m³. It is equipped with an HVAC system for the control all year of temperature and relative humidity, managed by a remote monitoring and control system. The AHU, housed in an attic room, allows for centralized air treatment in summer mode, while, in winter mode, there is also the possibility of post-heating by means of zone batteries; the outdoor air intake is on the roof and there are variable flow fans (nominal air flow rate of 9000 m³/h). Air inlet and outlet takes place through floor grids with adjustable nozzles.

Room 160 (Figure 3c) has a north-west oriented windowless external wall and a skylight. It houses the collection donated by Contini-Bonacossi, with paintings and marble statues. Samplings were carried out near the precious paintings. The room has a floor area of 89.10 m², a height of 3.17 m and a volume of 282.45 m³. It is equipped with an HVAC system for the control all year of temperature and relative humidity, managed by a remote monitoring and control system. The AHU, housed in a technical room located inside a storage area of the museum, allows centralized air treatment with recirculation in summer mode, while, in winter mode, there is also the possibility of post-heating by means of zone batteries; the outdoor air intake is on the roof and there are supply and return fans with variable flow (nominal air flow rate of 8000 m³/h). The air inlets grids are positioned at the top under the skylight and the air outlet grids are located at the bottom of the wall. In this room only, there is a system for continuous monitoring of CO₂ and VOCs owned by the museum.

The other six rooms analyzed are located on the second floor of the building (Figure 4). The entrance (Figure 4a) of the Uffizi Gallery overlooks a large corridor. It faces west with large windows and mainly hosts marble statues and paintings on canvas. Sampling was performed near the visitor control area. The entrance has a floor area of 317.14 m², a height of 5.68 m and a volume of 1801.35 m³. The space is equipped with nine fan coils placed in the internal wall of the corridor without air exchange. The recirculated indoor air is heated/cooled by the fan coil exchanger and then sent through a duct to the floor air inlets placed on the opposite side of the corridor. Inspection of the equipment is difficult.

The Verone II floor (Figure 4b) is a corridor connected to the entrance of the Gallery. It is north-, south- and west-oriented, with large windows, and mainly hosts marble statues and paintings on canvas. Sampling was performed near the west-facing window, an area without an air conditioning system. It has a floor area of 214.99 m², a height of 5.68 m and a volume of 1221.14 m³.

Room 2 (Figure 4c) has no external walls. Inside the room, the very famous “Maestà di Ognissanti” by Giotto (about 1310), a tempera and gold painting on wood, is displayed. Samplings were carried out near the painting. The room has a floor area of 198.27 m², a height of 9.85 m and a volume of 1952.96 m³. It is equipped with an HVAC system for the control all year of temperature and relative humidity, managed by a remote monitoring and control system. The AHU, housed in an attic room, allows all year centralized air treatment with recirculation and is equipped with supply and return fans with variable flow (nominal air flow rate of 8000 m³/h). The air inlet grids are positioned at the top of the roof, while the air outlet grids are located at the bottom of the opposite wall.

Room 10 (Figure 4d) has only an east-oriented windowless external wall. Inside the room there is the well-known “Primavera” by Sandro Botticelli, a tempera painting on wood (1478–1482). Samplings were carried out near the painting. The room has a floor area of 146.34 m², a height of 8.93 m and a volume of 1306.82 m³. It is equipped with an HVAC system for the control all year of temperature and relative humidity, managed by a remote monitoring and control system. The AHU, housed in an attic room, allows the centralized air treatment with air recirculation all year, and is equipped with supply and return fans with variable flow (nominal air flow of 8000 m³/h). The air inlet and outlet takes place through linear grids placed under the top skylight.




Figure 4. Analyzed rooms on the second floor of the Uffizi Gallery: (a) Entrance, (b) Verone II floor, (c) Room 2, (d) Room 10, (e) Room 35 and (f) Room 41.

Room 35 (Figure 4e) has one west-oriented windowless external wall. Inside the room there is the “Adorazione dei Magi” of Leonardo da Vinci, a tempera and oil painting (1481–1482). Samplings were carried out near the painting. It has a floor area of 146.80 m^2 , a height of 6.61 m and a volume of 970.35 m^3 . It is equipped with an HVAC system for the control all year of temperature and relative humidity, managed by a remote monitoring and control system. The AHU, housed in an attic room, allows centralized air treatment with air recirculation all year and is equipped with supply and return fans without variable flow (nominal air flow of $9500 \text{ m}^3/\text{h}$). The air inlet takes place through linear grids placed on the top of the ceiling while the air outlet occurs through floor grids.

Room 41 (Figure 4f) has one west-oriented windowless external wall. Inside the room there is the Sacra Famiglia, called “Tondo Doni”, of Michelangelo Buonarroti, a tempera painting on wood (1503–1504). The room samplings were carried out near the painting. The room has a floor area of 140.91 m^2 , a height of 6.61 m and a volume of 931.41 m^3 . It is equipped with an HVAC system for the control all year of temperature and relative humidity, managed by a remote monitoring and control system. The AHU allows centralized air treatment with air recirculation all year, and is equipped with supply and return fans without variable flow (nominal air flow of $10000 \text{ m}^3/\text{h}$). The air inlet takes place through linear grids placed on the top of the ceiling, near the skylight, while the air outlet occurs through floor grids. The AHU is located in a very narrow attic room, which is particularly difficult to access for maintenance purposes.

Measurement of the parameters mentioned in Section 2.1 (temperature, RH, CO_2 , VOCs, TBL and molds) were taken in sequence in each analyzed room, at the time of the greatest number of visitors, according to the schedule shown in Table 7. To evaluate the influence of occupants on pollutant concentrations, in Room 10, all the measurements

were carried out during both a closed and an open day. Furthermore, in Room 35 and Room 41, the Uffizi Gallery Directorate also requested the measurement of temperature, relative humidity and carbon dioxide on a closed day of the museum.

Table 7. Schedule of IAQ measurements in the Uffizi Gallery of Florence.

Analyzed Rooms	Day	Notes
I floor		
Verone I floor	6 June 2019	Museum open
Room 160	6 June 2019	Museum open
Room 71	6 June 2019	Museum open
II floor		
Room 10	3 June 2019	Museum closed
	5 June 2019	Museum open
Entrance	5 June 2019	Museum open
Room 2	5 June 2019	Museum open
Verone II floor	5 June 2019	Museum open
Room 35	3 June 2019	Museum closed (only for t, RH and CO ₂)
	5 June 2019	Museum open
Room 41	3 June 2019	Museum closed (only for t, RH and CO ₂)
	5 June 2019	Museum open

To quantify the presence of visitors during monitoring days, the number of tickets sold was taken into account. On 5 June, 7435 visitors were counted, while on 6 June 7297 visitors were recorded.

Figure 5 shows the equipment for IAQ monitoring positioned in a representative room of the case study (Room 160).



■ t, RH and CO₂

● VOCs

◆ TBL and molds (active sampling)

* TBL and molds (passive sampling)

Figure 5. Equipment for IAQ monitoring positioned in a representative room of the Uffizi Gallery (Room 160).

3. Results

The results of the monitoring carried out within the selected rooms of the Uffizi Gallery are reported according to the type of analyzed parameter (i.e., air temperature and relative humidity, carbon dioxide concentration, total volatile organic compounds and biological pollutants).

Figure 6 shows, for each analyzed room and monitoring period, the minimum, average, and maximum measured values for air temperature (t) and relative humidity (RH).

The values were compared with narrow ranges considered acceptable for both artwork conservation (paintings— $19 \div 24$ °C for temperature and $45 \div 65\%$ for relative humidity [30]) and for the comfort of people ($20 \div 26$ °C for temperature and $40 \div 60\%$ for relative humidity [20,21]), i.e., $20 \div 24$ °C for temperature and $45 \div 60\%$ for relative humidity.




Figure 6. Minimum, average and maximum measured values for temperature (t [°C]) and relative humidity (RH [%]) compared together with recommended values.

Figure 7 shows, for each analyzed room and monitoring period, the minimum, average and maximum measured values for carbon dioxide concentration, which were compared with value ranges considered acceptable for people, i.e., 1000 ppm [12].




Figure 7. Minimum, average and maximum measured values for carbon dioxide concentration (CO₂ [ppm]) compared together with value ranges considered acceptable for people.

In Figure 8, for each analyzed room, the measured values for VOCs concentration are reported and compared with comfort ($<0.200 \text{ mg/m}^3$) and acceptable ($0.200 \div 3 \text{ mg/m}^3$) values for these pollutants [10,12]. For Room 10, one of the most visited areas, samples were also taken on a closed day of the museum (3 June 2019), during which there was only one guided tour by a small group of visitors at 11:00, while the measurement of 13:00 refers to the museum totally without visitors.




Figure 8. Sampled values for VOCs (mg/m^3) in the analyzed rooms of the Uffizi Gallery compared with comfort ($<0.200 \text{ mg/m}^3$) and acceptable ($0.200 \div 3 \text{ mg/m}^3$) values for people.

Figure 9 reports, for each analyzed room, the results of the sampling carried out for biological pollutants compared with reference values reported in Table 4. The results expressed in CFU/m^3 were obtained from active sampling, while those expressed in CFU/PT90 refer to passive sampling of TBL and mold. The greater concentration detected by active sampling compared to passive is a natural consequence of the sampling technique: passive sampling does not force the capture of microorganisms and, thus, lower values are expected.




Figure 9. Values for biological pollutant sampling in the analyzed rooms of the Uffizi Gallery compared with reference values for TBL and molds.

4. Discussion

The results of the monitoring highlight some issues for the assessment of microclimatic parameters and IAQ pollution.

With respect to the microclimatic parameters (Figure 6), the measured values compared with the recommended ranges showed acceptable values for air temperature in the majority of the rooms—in some of them the values were only slightly over the limit value. For relative humidity, the values were above the limits when the museum was closed to the public in Room 10, Room 35, and Room 41. For the temperature values, the environment with the highest values (over 26 °C), which went beyond the conservation levels of the paintings and the comfort of people, was the Verone II floor, which had no HVAC systems. By comparison between data collected in the rooms with the museum closed and when open to the public, it was observed that when the museum was closed, the temperature and relative humidity values were often outside the optimal ranges. In particular, when the museum was closed, the temperature had lower values and the relative humidity higher values, even reaching 70% in Room 10 and Room 41. These data suggest that when the museum was closed, with climatic conditions that were not critical for a lack of sensible heat due to the occupants, the temperature was lower due to the absence of the public; under these conditions, the HVAC system was not able to control the relative humidity as it was not working under standard operating conditions. The fluctuations in the above-mentioned parameters must, therefore, be carefully assessed so that they do not cause damage to the artefacts of the museum.

To guarantee and maintain optimal microclimatic conditions for the correct conservation of the objects displayed, variation in the temperature and relative humidity values must be carefully monitored, in particular, where paintings on wood are exposed. The best conditions are those that address, at the same time, air conditioning requirements, energy saving needs and the architectural constraints of the museum operating in an historic ancient building.

For carbon dioxide, the rising values sampled in some museum rooms can be related to the presence of visitors and staff, to outdoor pollution and to the non-optimal positioning of the air inlet and outlet grids of the HVAC system.

As shown in Figure 7, the threshold value was exceeded in the most crowded rooms, Room 2 and Room 10, and at the entrance of the museum, where there was always a queue. During opening hours, the average values in Room 2 reached 1516 ppm, in Room 10 1442 ppm, while in the Entrance, an environment without air exchange and with a greater concentration of public visitors, CO₂ average values of 2183 ppm were measured, with peaks of 2404 ppm. In the Verone II floor, also without mechanical ventilation, much lower CO₂ average values were recorded, equal to 1055 ppm, probably due to the lower concentration of visitors.

The comparison between the measured values of the CO₂ concentration in the presence of visitors (average concentration in Room 10, Room 35, and Room 41 equal to about 1049 ppm) and when the museum was closed (average concentration in Room 10, Room 35, and Room 41 equal to about 540 ppm) made it possible to evaluate the influence of the presence of the public, which was associated with an approximate doubling of the background concentration of CO₂ in rooms with mechanical ventilation.

Figure 10 shows the trend in CO₂ concentration measured by the continuous monitoring system owned by the museum and present only in Room 160 from 3 to 6 June 2019; these data are in line with those monitored during the spot campaign (with a difference of about 5%). The CO₂ minimum value measured in Room 160 in this period was 530 ppm (museum closed) while the maximum value was 1040 ppm (museum open). This background concentration of CO₂ is consistent with the average Italian data measured outdoors in 2019 and equal to 410 ppm [38], considering that there were still people present in the museum even during closing hours (staff, restorers, maintenance workers, etc.). The graph also shows that the highest concentration of CO₂ was reached between 10:30 and 16:00, indicating that these times were also those with the greatest turnout of visitors.




Figure 10. Trend of CO₂ values (ppm) for the period from 3 to 6 June 2019 detected by the continuous monitoring system in Room 160 owned by the museum.

Regarding the VOCs concentration (Figure 8), comparison of the values from sampling carried out in Room 10 when the museum was closed with days of high visitor turnout confirmed the hypothesis of human influence on the release of volatile organic compounds. The two VOCs values relating to the first and second sampling in Room 10 on the day of closure to the public provide significant information on the effectiveness and importance of the air exchange provided by the ventilation system: two hours between the passage of the first group of visitors (11:00) and the following group (13:00) were sufficient to reduce the VOCs concentration by 44%.

The values compared with the recommended limits reported in Table 3 showed comfortable (Room 35, Room 41, and Room 71) or acceptable levels for the VOCs concentrations.

Furthermore, many VOCs classes (halogen-aliphatic, halogen-aromatic, halogen-unsaturated, nitrogen-aromatic, oxygen-acid, ether, oxygen-acid, phenol, sulfur-mercaptan, sulfur-sulphide) were not detected. For the VOCs classes that were detected, to evaluate the contribution and investigate the origin, the cut-off value of the compound was set at 1%. This value represents the concentration of the pollutant in the compound to be considered significantly present. The most present classes in the monitored rooms were aldehydes and alcohols, which were highlighted by the sum of the concentration values of the individual VOCs classes. As previously mentioned, these pollutants are present in furnishings, and especially in cleaning products (perfumes, deodorants, additives to cleaning products) and disinfectants, but their concentration can also be related to the presence of visitors. In particular, the values of aldehydes were higher at the second floor entrance, where all visitors pass through before being distributed to the different rooms, and where there was no mechanical ventilation. High and persistent concentrations of aldehydes can be associated with respiratory problems in sensitive subjects.

Table 8 summarizes the substances with concentrations greater than or equal to the cut-off values for each sampling point.

As the CO₂ and VOCs trends were similar, strategies to improve the IAQ can be effective for the control of both CO₂ and VOCs.

The analysis of the biological pollutants (Figure 9) confirmed the data that emerged from the chemical investigation: the sampling point most vulnerable to the concentration of biological pollutants was the entrance on the second floor. Based on the reference values shown in Table 4, the following observations can be made: the concentration of TBL in all the rooms was at a mean pollution level (less than 500 CFU/m³), while the concentration

of mold in all the rooms was at a low pollution level (less than 100 CFU/m³). Nevertheless, these biological pollutants must be constantly monitored as indicators of indoor air quality, together with the other inorganic and organic pollutants.

Table 8. VOCs classes and relative concentrations (mg/m³) in the analyzed rooms of the Uffizi Gallery.

VOCs Classes	Entrance II Floor	Room 2	Room 10	Verone II Floor	Room 35	Room 41	Room 71	Room 160	Verone I Floor	Total Sum
Cut off	0.006	0.004	0.002	0.002	0.002	0.002	0.002	0.002	0.002	
Alicyclic hydrocarbons	0.007	0	0	0	0	0.002	0	0.002	0	0.011
Aromatic hydrocarbons	0.012	0.009	0	0.013	0.014	0.018	0.004	0.003	0.021	0.094
Define hydrocarbons	0.014	0.009	0.008	0	0	0	0	0	0	0.031
Paraffins	0.109	0.007	0.016	0.009	0.004	0.015	0.006	0.019	0	0.185
Terpens hydrocarbons	0	0.005	0	0.007	0.003	0.002	0.002	0.004	0.002	0.025
Oxygenated—acids	0.026	0.018	0.025	0.016	0.007	0.009	0.009	0.007	0.016	0.133
Oxygenated—alcohols	0.099	0.111	0.034	0.091	0.058	0.083	0.065	0.064	0.066	0.671
Oxygenated—aldehydes	0.124	0.099	0.092	0.063	0.071	0.064	0.061	0.064	0.088	0.726
Oxygenated—ketones	0.060	0.033	0.045	0.011	0.017	0.008	0.005	0.012	0.009	0.200
Oxygenated—esters	0.008	0	0.005	0.003	0.005	0.005	0.008	0.008	0.004	0.046

The observed environmental molds were of the *Aspergillus* and *Penicillium* genera. The first species is ubiquitous and, therefore, is often monitored in different environments. *Flavus* and *Fumigatus* species (classified in [31] as allergenic molds) were recorded, while *Aspergillus niger* was not identified. *Penicillium* genera can generate respiratory tract disorders in predisposed or immunosuppressed subjects.

Table 9 summarizes and compares the main values detected during the indoor monitoring campaign with the main characteristics of the HVAC systems present in the respective analyzed rooms. From the data, it is clear that the high concentrations of CO₂ could have been partly due to the modalities of introduction and extraction of the air in the environment that can negatively influence the air exchange. For example, Room 10 was served by a system with air inlet and outlet from the ceiling with possible short circuit. For Room 71, the air inlet and outlet were from the floor with possible similar problems, aggravated by the poor cleaning of the floor grilles. In the case of Room 2, even in the presence of air intake from above and return of air from below, the air flow rates may not have been adequate. In particular, the higher CO₂ concentrations corresponded to lower air changes.

Table 9. Comparison among the main values detected during the indoor monitoring campaign and the main characteristics of the HVAC systems present in the analyzed rooms.

Room	HVAC System	V * [m ³]	A _{fr} ** [m ³ /h]	A _{er} *** [vol/h]	Ave t [°C]	Ave UR [%]	Ave CO ₂ [ppm]	VOCs [mg/m ³]	TBL [CFU/m ³]	Mold [CFU/m ³]
Verone I floor	Primary ventilation air floor inductors; no recirculated air.	1642.5	1400	1.70	22	51	650	0.222	262	27
Room 71	Air inlet and outlet floor grids	2598.5	9000	3.46	24	51	1156	0.188	242	56
Room 160	Air inlets grids near the skylight and air outlet grids at the bottom of the wall	1260.7	8000	6.35	23.9	52	859	0.254	305	30

Table 9. Cont.

Room	HVAC System	V * [m ³]	A _{fr} ** [m ³ /h]	A _{er} *** [vol/h]	Ave t [°C]	Ave UR [%]	Ave CO ₂ [ppm]	VOCs [mg/m ³]	TBL [CFU/m ³]	Mold [CFU/m ³]
Room 2	Air inlets grids at the top of the roof and air outlet grids at the bottom of the opposite wall.	1953.0	8000	4.10	22.3	53	1516	0.362	154	28
Room 10	Air inlet and outlet linear grids near the skylight	1306.8	8000	6.12	22.8	51	1442	0.354	180	19
Room 35	Air inlet linear grids near the skylight and air outlet floor grids	970.4	9500	9.79	23.3	48	807	0.196	190	56
Room 41	Air inlet linear grids near the skylight and air outlet floor grids	931.4	10,000	10.74	24.6	49	899	0.220	114	66
Entrance	Only recirculated air through wall fan coils and air inlet floor grids; no air exchange	4941.5	-	-	24.9	53	2183	0.571	380	54
Verone II floor	No HVAC system	1221.1	-	-	24.9	47	1055	0.236	142	61

* volume; ** nominal air flow rate; *** air exchange rate.

5. Conclusions

This paper presents an approach for the assessment of IAQ in museum buildings taking into account both artwork conservation and visitor well-being. The proposed approach was implemented and applied in the world-famous Uffizi Gallery of Florence. Some representative rooms within the museum were identified and monitored over the short-term to assess relevant IAQ-related parameters, including the concentration of chemical (CO₂, VOCs) and biological pollutants (TBL and molds), in relation to microclimatic parameters (t, RH).

No pathogens (microbiological) or chemical agents (concentrations of VOCs and CO₂) were detected such as to require urgent intervention to eliminate potentially dangerous situations; however, IAQ can be improved through both simple and more complex interventions.

Based on consideration of the indoor air pollution and the effectiveness of the HVAC systems in the Uffizi Gallery, some guidelines, that can be generalized for similar applications, are summarized below:

- Thermo-hygrometric parameters: Check the HVAC regulation control system of the thermo-hygrometric parameters, especially on days when the museum is closed to the public, when the HVAC system may not be able to control these parameters to guarantee optimal ranges for both conservation and wellbeing;
- Carbon dioxide concentration: Increase the air flow rate, if possible, and ensure it is controlled based on CO₂ monitoring. Modification of the air distribution (inlet and outlet grids) can be achieved more easily with furnishing interventions; however, when these actions affect wall structures, their feasibility must be carefully assessed, especially in historical buildings. Consider the possibility of equipping the museum with a fixed CO₂ monitoring system;
- Volatile organic compound concentration: Although ventilation is a fundamental strategy for improving indoor air quality, the best way to maintain the quality of indoor air is to reduce sources of pollution indoors. After short-term monitoring, it is suggested that monitoring of VOCs is extended through targeted sampling of the most represented pollutants. Moreover, cleaning, sanitizing, disinfecting products and other products used for the maintenance of the building-plant system, can increase indoor air pollution as they can produce VOCs. To control IAQ, the composition of the chemicals used in the building must be checked and assessed. If dangerous or irritant substances are detected, green cleaning options, instead of chemical products containing high levels of VOCs, represents a safer and healthier strategy to prevent unsafe exposure and health effects, both for visitors and staff;

- Microbiological pollutants: It is suggested that biological monitoring is extended to investigate the presence of microbiological agents in the airduct, on the air inlet and outlet grids, as well as on the filters, before and after washing/replacement operations;
- HVAC Systems: The close relationship that exists between overall hygiene levels of airducts and IAQ (concentration of dust in the ducts and level of microbial and fungal contamination of the dust) suggests that operational protocols regarding the hygienic maintenance of HVAC systems, following the procedures according to the NADCA and the Guidelines of the State-Regions Agreements, must be consistently applied;
- IAQ Monitoring upgrade: In general, to guarantee a healthy workplace, specific contaminants belonging to the more representative classes of VOCs, and chemical and biological pollutants must be thoroughly investigated and monitored for at least 8 h, considering DL 81/2008 that defines both TLV—TWA (threshold limit value—time weighted average) and TLV—STEL (threshold limit value—short-term exposure limit). TLV—TWA is the limit value for eight hours daily of exposure \times five days a week (for the workers), while the TLV—STEL value represents the average concentrations that can be reached by the various pollutants for a maximum period of 15 min (for visitors). Moreover, to establish an accurate correlation between indoor pollution, HVAC system hygienic conditions and air distribution effectiveness in the museum rooms, long-term monitoring must be planned, together with survey of the hourly trends in the number of visitors, and the sampling of specific pollutants, to be performed not only in the environment, but also in the HVAC system sections (air duct, grids, filters, etc.), before and after undertaking hygienic maintenance procedures of the system.

Author Contributions: Conceptualization, F.S., C.C. and G.C.; methodology, F.S., C.C., G.C. and C.P.; supervision, F.S., C.C., G.C. and C.P.; writing—original draft, F.S. and C.C.; writing—review and editing, F.S., C.C. and C.P. All authors have read and agreed to the published version of the manuscript.

Funding: This research received no external funding.

Institutional Review Board Statement: Not applicable.

Acknowledgments: The authors would like to acknowledge the museum staff, especially in the persons of the Director Eike D. Schmidt and Giuseppe Russo, for providing support and co-operation during the process of collecting data, and the IDIS Laboratory, especially in the person of Elena Baistrocchi, for collaboration in the analyses of chemical and microbiological monitoring. C.P. would like to thank the Italian funding programme Fondo Sociale Europeo REACT EU—Programma Operativo Nazionale Ricerca e Innovazione 2014–2020 (European Social Fund REACT EU—National Operational Program for Research and Innovation 2014–2020) (D.M. n.1062 del 10 August 2021) for supporting her research. This paper is a revised and expanded version of this conference paper presented at the Florence Heri-Tech 2020 International Conference: Carletti, C.; Cellai, G.; Sciarpi, F.; Russo, G.; Schmidt, E.D., Indoor Air Quality in the Uffizi Gallery of Florence: Sampling Methodology and Preliminary Results», IOP Conference Series: Materials Science and Engineering 949, 2020, 1, <https://doi.org/10.1088/1757-899X/949/1/012016>.

Conflicts of Interest: The authors declare no conflict of interest.

References

1. Silva, E.H.; Henriques, F.M.A. The impact of tourism on the conservation and IAQ of cultural heritage: The case of the Monastery of Jerónimos (Portugal). *Build. Environ.* **2021**, *190*, 107536. [CrossRef]
2. Lucchi, E. Environmental Risk Management for Museums in Historic Buildings through an Innovative Approach: A Case Study of the Pinacoteca di Brera in Milan (Italy). *Sustainability* **2020**, *12*, 5155. [CrossRef]
3. Thomson, G. *The Museum Environment*, 2nd ed.; Butterworth—Heinemann: London, UK, 1986.
4. Manfriani, C.; Gualdani, G.; Goli, G.; Carlson, B.; Certo, A.R.; Mazzanti, P.; Fioravanti, M. The Contribution of IoT to the Implementation of Preventive Conservation According to European Standards: The Case Study of the “Cannone” Violin and Its Historical Copy. *Sustainability* **2021**, *13*, 1900. [CrossRef]

5. Ilies, D.C.; Safarov, B.; Caciara, T.; Ilies, A.; Grama, V.; Ilies, G.; Huniadi, A.; Zharas, B.; Hodor, N.; Sandor, M.; et al. Museal Indoor Air Quality and Public Health: An Integrated Approach for Exhibits Preservation and Ensuring Human Health. *Sustainability* **2022**, *14*, 2462. [CrossRef]
6. Pisello, A.L.; Castaldo, V.L.; Piselli, C.; Cotana, F. Coupling artworks preservation constraints with visitors' environmental satisfaction: Results from an indoor microclimate assessment procedure in a historical museum building in central Italy. *Indoor Built Environ.* **2018**, *27*, 846–869. [CrossRef]
7. Coelho, G.B.A.; Silva, H.E.; Henriques, F.M.A. Impact of climate change on cultural heritage: A simulation study to assess the risks for conservation and thermal comfort. *Int. J. Glob. Warm.* **2019**, *19*, 382. [CrossRef]
8. Sciarpi, F.; Carletti, C.; Pierangioli, L. Assessment of thermo-hygrometric indicators for preventive conservation inside museums: In field monitoring and passive microclimatic control strategies applied to “la Specola” museum of Florence. *IOP Conf. Ser. Mater. Sci. Eng.* **2018**, *364*, 012023. [CrossRef]
9. Tetreault, J. *Airborne Pollutants in Museums, Galleries and Archives: Risk Assessment, Control Strategies and Preservation Management*; Canadian Conservation Institute: Ottawa, ON, Canada, 2003.
10. Maroni, M.; Seifert, B.; Lindvall, T. *Indoor Air Quality. A Comprehensive Reference Book*; Elsevier: Amsterdam, The Netherlands, 1995.
11. Silva, E.H.; Henriques, F.M.A. Indoor Climate Management of Museums: The Impact of Ventilation on Conservation, Human Health and Comfort. In *Occupant Behaviour in Buildings: Advances and Challenges*; Ghisi, E., Forgiarini Rupp, R., Fernandes Pereira, P., Eds.; Bentham Science Publishers LTD: Sharjah, United Arab Emirates, 2021; pp. 275–323.
12. ISS. Available online: https://www.iss.it/en/rapporti-istisan/-/asset_publisher/Ga8fOpve0fNN/content/16-15 (accessed on 26 July 2022).
13. Ministero Della Salute, Repubblica Italiana. Available online: https://www.salute.gov.it/portale/documentazione/p6_2_5_1.jsp?lingua=italiano&id=283 (accessed on 26 July 2022). (In Italian)
14. Leung, D.Y.C. Outdoor-indoor air pollution in urban environment: Challenges and opportunity. *Front. Environ. Sci.* **2015**, *2*, 1–7. [CrossRef]
15. Nazaroff, W.; Weschler, C.J. Cleaning products and air fresheners: Exposure to primary and secondary air pollutants. *Atmos. Environ.* **2004**, *38*, 2841–2865. [CrossRef]
16. EC. Available online: <https://eur-lex.europa.eu/legal-content/IT/TXT/PDF/?uri=CELEX:02008R1272-20180301&from=DE> (accessed on 26 July 2022). (In Italian).
17. COST Project 6 1 3. Available online: <https://op.europa.eu/en/publication-detail/-/publication/a536eeb5-beb8-11e7-a7f8-01aa75ed71a1> (accessed on 26 July 2022).
18. ISS. Available online: https://www.iss.it/documents/20126/45616/ONLINE_APRILE.pdf/c45a9e17-b601-a95d-f64b-d652a84bd9e8?t=1581100961065 (accessed on 26 July 2022). (In Italian).
19. COST Project 613. Available online: https://www.aivc.org/sites/default/files/members_area/medias/pdf/Inive/ECA/ECA_Report12.pdf (accessed on 26 July 2022).
20. UNI EN ISO 7730: 2006; Ergonomics of the Thermal Environment. Analytical Determination and Interpretation of Thermal Comfort Using Calculation of the PMV and PPD Indices and Local Thermal Comfort Criteria. UNI—Ente Italiano di Normazione: Milan, Italy, 2006.
21. Ministero Della Salute. Available online: https://www.salute.gov.it/portale/temi/p2_6.jsp?id=4387&area=indor&menu=vuoto (accessed on 30 July 2022). (In Italian)
22. ISS. Available online: https://www.iss.it/documents/20126/45616/16_15_web.pdf/a9142047-b81d-3e0b-6e6f-10860f855b67?t=1581099182421 (accessed on 26 July 2022). (In Italian).
23. COST Project 613. Available online: https://www.aivc.org/sites/default/files/members_area/medias/pdf/Inive/ECA/ECA_Report11.pdf (accessed on 26 July 2022).
24. ANSI/ASHRAE Standard 62.1: 2019; Ventilation for Acceptable Indoor Air Quality. ASHRAE: Atlanta, GA, USA, 2019.
25. UNI EN 16798-17:2018; Energy Performance of Buildings—Ventilation for Buildings—Part 17: Guidelines for Inspection of Ventilation and Air Conditioning Systems (Module M4-11, M5-11, M6-11, M7-11). UNI—Ente Italiano di Normazione: Milan, Italy, 2018.
26. UNI EN 16798-1:2019; Energy Performance of Buildings—Ventilation for Buildings—Part 1: Indoor Environmental Input Parameters for Design and Assessment of Energy Performance of Buildings Addressing Indoor Air Quality, Thermal Environment, Lighting and Acoustics—Module M1-6. UNI—Ente Italiano di Normazione: Milan, Italy, 2019.
27. ISS. Available online: https://www.iss.it/en/rapporti-istisan/-/asset_publisher/Ga8fOpve0fNN/content/13-4 (accessed on 26 July 2022).
28. ISS. Available online: https://www.iss.it/en/rapporti-istisan/-/asset_publisher/Ga8fOpve0fNN/content/13-37 (accessed on 26 July 2022).
29. ISS. Available online: https://www.iss.it/en/rapporti-istisan/-/asset_publisher/Ga8fOpve0fNN/content/15-25 (accessed on 26 July 2022).
30. D.M. 10 Maggio 2001; Atto di indirizzo sui criteri tecnico-scientifici e sugli standard di funzionamento e sviluppo dei musei (Art. 150, comma 6, del D.Les. n. 112 del 1998). Gazzetta Ufficiale 19 ottobre 2001, n. 244, S.O. Ministero per I Beni E Le Attività Culturali, Repubblica Italiana: Rome, Italy, 2001. (In Italian)

31. *lgs. 9 aprile 2008, n. 81*; Testo unico sulla salute e sicurezza sul lavoro, Attuazione dell'articolo 1 della Legge 3 agosto 2007, n. 123 in materia di tutela della salute e della sicurezza nei luoghi di lavoro. Gazzetta Ufficiale 30 aprile 2008, n. 101 —Suppl. Ordinario n. 108. Repubblica Italiana: Rome, Italy, 2008. (In Italian)
32. Conferenza Stato—Regioni. Available online: <http://www.omceofg.it/wp-content/uploads/2017/04/PattoSalute56af.pdf> (accessed on 26 July 2022). (In Italian).
33. Conferenza Stato—Regioni. Available online: <http://www.regioni.it/news/2013/02/21/conferenza-stato-regioni-del-07-02-2013> (accessed on 26 July 2022). (In Italian).
34. NADCA. Available online: <https://nadca.com/store/acr-nadca-standard-2021-edition> (accessed on 26 July 2022).
35. Carletti, C.; Cellai, G.; Sciarpi, F.; Russo, G.; Schmidt, E.D. Indoor Air Quality in the Uffizi Gallery of Florence: Sampling Methodology and Preliminary Results». *IOP Conf. Ser. Mater. Sci. Eng.* **2020**, *949*, 1. [CrossRef]
36. United States Environmental Protection Agency EPA. Available online: https://19january2017snapshot.epa.gov/sites/production/files/2015-07/documents/epa-to-15_0.pdf (accessed on 30 July 2022).
37. EC. Available online: <https://osha.europa.eu/it/legislation/directives/regulation-ec-no-1272-2008-classification-labelling-and-packaging-of-substances-and-mixtures> (accessed on 30 July 2022).
38. IPCC. Available online: <https://ipccitalia.cmcc.it/messaggi-chiave-ar6-wg1/#> (accessed on 2 August 2022).